

- FLASHINGS OR SIDING.
- 3. IF A CONDUIT GREATER THAN 10 FT. IN TOTAL LENGTH IS REQUIRED, THE THREADED COUPLING AND SHORT PIECE MUST BE ON THE END ADJACENT TO THE METER BASE.
- 4. FOR SERVICE DROPS LESS THAN 750 VOLTS, AN 18" CLEARANCE IS ALLOWED WHEN NO MORE THAN 6'-0" OF THE SERVICE PASSES OVER THE ROOF AND TERMINATES ON A SERVICE MAST. THE SERVICE MAST CANNOT BE MORE THAN 4'-0" FROM THE EDGE OF THE ROOF.
- 5. IF EXTERIOR CABLE EXIT IS UTILIZED FOR THE MEMBER'S SERVICE CONDUCTOR, THE SERVICE CONDUCTOR MUST BE ENCLOSED IN AN APPROVED CONDUIT PER NEC 230.50 (SCHEDULE 40 PVC, RIGID METAL CONDUIT, ETC.) TO A LEVEL 18" BELOW FINAL GRADE.
- 6. ANTIOXIDANT COMPOUND IS REQUIRED ON ALL CONNECTIONS TO ALUMINUM CONDUCTORS.
- 7. METER MUST BE READILY ACCESSIBLE WITH NO OBSTRUCTIONS. A CLEAR WORK AREA WITH AN 18" CLEARANCE ON ALL SIDES AND A 36" CLEARANCE IN FRONT OF METER BASE IS REQUIRED. THIS CLEARANCE MUST EXTEND TO A HEIGHT OF 84"

4				DATE: 2-11-05	OVERHEAD SERVICE - PIPE MAST	SPEC. NO.
				DRAWN BY:	STANDARD ELECTRIC SERVICE	
				APP'D BY:	REQUIREMENTS CULLMAN ELECTRIC	OH-3
	NO.	REVISION	DATE		COOPERATIVE CULLMAN, ALABAMA	